



Zilla Panchayat Mandya

District Drinking Water Examining laboratory

Rural Drinking Water and Purification Division Mandya

Taluk: Mandya

Samples collecting date:25.02.2015

JSS Public School

S.N	Rural Name	Drinking Water Plan			Details of location	Examination of quality Samples results													Remarks
		PWS	MWS	HP		Turbidity	Hardness	Chloride	Alkalinity	P.H	Fluoride	Nitrate	Iron	Sulphate	Calcium	T.D.S	Conductivity	Bacteria	
						05-Oct	300-600	250-1000	600	6.5-8.5	1-1.5	45	0.3-0.3	200-400	75-200	500-2000	770-3080	10-100	
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
1	Kent Purified Water				School	0.01	40	28	80	6.02	0.18	1.24	0.01	0.8	16	0	0	Nil	-
1	Borewell Water				School	0.2	490	198	580	7.30	0.46	1.96	0.02	30.8	96	300	600	Nil	

Report (1) & (2) Potable



Coordinator

Drinking Water examining laboratory

Panchayat Raj Division,
Mandya